



中国国家强制性产品认证证书

证书编号: 2008010307297322

委托人名称、地址

埃伯斯电子(上海)有限公司
上海市怒江北路561弄4号楼2楼

生产者(制造商)名称、地址

埃伯斯电子(上海)有限公司
上海市怒江北路561弄4号楼2楼

生产企业名称、地址

埃伯斯电子(上海)有限公司宝应分公司
江苏省宝应经济开发区泰山东路9号

产品名称和系列、规格、型号

设备用断路器

IEL, IUL, IML, CEL, CML, LEL, LML; 参见附件

产品标准和技术要求

GB 17701-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2016年03月10日

有效期至: 2021年03月10日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2008年09月28日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1343243



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2008010307297322

NAME AND ADDRESS OF THE APPLICANT

Airpax Electronic(Shanghai)Co.,Ltd
2F,NO.4 Building Lane 561,Nujiang Rd. (N)Shanghai

NAME AND ADDRESS OF THE MANUFACTURER

Airpax Electronic(Shanghai)Co.,Ltd
2F,NO.4 Building Lane 561,Nujiang Rd. (N)Shanghai

NAME AND ADDRESS OF THE FACTORY

Airpax Electronic(Shanghai)Co.,Ltd Baoying Branch
9 East Taishan Road Baoying Economic Development Zone, Jiangsu

NAME, MODEL AND SPECIFICATION

Circuit Breaker for equipment

IEL, IUL, IML, CEL, CML, LEL, LML; see the appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 17701-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-C03-02:2014).

Date of issue: Mar.10,2016 Date of expiry: Mar.10,2021

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Sep.28,2008

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1343243



中国国家强制性产品认证证书

附录:

第 1 页 共 2 页

证书编号: 2008010307297322

纸号: 1343243

IEL、IUL、IML、CEL、CML、LEL、LML

Ue: DC65V,DC80V,DC125V,AC250V,AC415V;

In:0.1~100A(0.10,0.20,0.30,0.40,0.50,0.60,0.70,0.80,0.90,1.00,1.10, 1.25, 1.40,1.50,1.75,2.00,2.20,2.25,2.50,2.75,2.90,3.00,3.10,3.20,3.25,3.50,3.60, 3.75,4.00,4.25,4.50,4.75,5.00,5.25,5.50,5.75,6.00,6.25,6.30,6.50,6.75,7.00, 7.25,7.50,7.75,8.00,8.25,8.50,9.00,9.25,9.50,10.0,10.5,11.0,11.5,12.0,12.5, 13.0,13.5,14.0,14.5,15.0,15.5,16.0,16.5,17.0,17.5,18.0,18.5,19.0,19.5,20.0, 21.0,22.0,23.0,24.0,25.0,25.5,26.0,27.0,28.0,29.0,30.0,31.0,31.5,32.0,33.0, 35.0,36.0,37.0,38.0,39.0,40.0,41.0,42.0,43.0,44.0,45.0,46.0,47.0,48.0,49.0, 50.0,51.0,52.0,53.0,54.0,55.0,56.0,57.0,58.0,59.0,60.0,61.0,62.0,63.0,64.0, 65.0,66.0,67.0,68.0,69.0,70.0,71.0,72.0,73.0,74.0,75.0,76.0,77.0,78.0,79.0, 80.0,81.0,82.0,83.0,84.0,85.0,86.0,87.0,88.0,89.0,90.0,91.0,92.0,93.0,94.0, 95.0,96.0,97.0,98.0,99.0,100A);

操作方式: S 型;

极数: 1P,2P,3P, 4P;

lcn:见下表

产品系列	IEL (IEL, IELX, IELZX, IELBX, IELK, IELZXX, IELBXX, IELXK, IELXC, IELH, IELHK), IUL(IUL,IULX, IULZX, IULBX, IULK, IULXK, IULBXX, IULZXX, IULNK, IULH, IULHK), IML (IML, IMLX, IMLZX, IMLBX, IMLXK, IMLZXX, IMLBXX, IMLN, IMLH, IMLHK)			
额定电流(A)	额定电压 (V)	额定短路能力(A)	最少极数	最大极数
0.1-50	80 DC	4000	1	4
51-100	80 DC	4000	1	3

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 2 页 共 2 页

证书编号: 2008010307297322

纸号: 1343243

0.1-70	65 DC	4000	1	4
0.1-100	250 AC	2000	1	4
0.1-50	415 AC	2000	2	4

产品系列	CEL (CEL, CELH, CELK, CELHK, CELZX, CELBX, CELZXK, CELBXK), CML (CML, CMLH, CMLK, CMLHK, CMLZX, CMLBX, CMLZXK)			
额定电流(A)	额定电压 (V)	额定短路能力(A)	最少极数	最大极数
0.1-70	125 DC	3000	1	3 (4)
0.1-100	80 DC	2000	1	3 (4)

产品系列	LEL (LEL, LELH, LELK, LELHK, LELZX, LELZXK, LMLZX, LMLBX, LELBXK), LML (LML, LMLH, LMLK, LMLHK, LMLBX, LMLBXK)			
额定电流(A)	额定电压 (V)	额定短路能力(A)	最少极数	最大极数
0.1-100	80 DC	2000	1	3 (4)
0.1-50	250 AC	2000	1	3 (4)

配用的辅助触头 (本体);

使用类别:

AC-12:Ue/Ie:125V/1A,250V/10A;

DC-12:Ue/Ie:80V/1A;

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

